

1. SEWER AND WATER SYSTEMS ARE TO BE CONSTRUCTED IN GENERAL ACCORDANCE WITH ALL YORK COUNTY AND SCDHEC REGULATIONS, REFERENCE SEWER AND WATER STANDARDS AND PROJECT SPECIFICATIONS.
2. SEWER AND WATER CONSTRUCTION ON THIS SITE IS AUTHORIZED BY PERMITS ISSUED BY THE SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL (SCDHEC). THE WORK IS SUBJECT TO INSPECTION AT ALL TIMES BY REPRESENTATIVES OF SCDHEC, YORK COUNTY, AND THE ENGINEER OF RECORD. THE PERMITS REQUIRE CERTIFICATION OF COMPLETION BY THE ENGINEER OF THE WATER AND SEWER SYSTEMS PRIOR TO THE ISSUANCE OF FINAL OPERATIONAL APPROVAL BY SCDHEC.
3. CONTRACTOR SHALL VERIFY THE ACTUAL LOCATION AND ELEVATION FOR ALL UTILITIES, DRAINAGE, AND OTHER UNDERGROUND FACILITIES, AND SHALL NOTIFY THE ENGINEER OF RECORD OF ANY DISCREPANCY OR CONFLICTS PRIOR TO CONSTRUCTION.
4. CONTRACTOR SHALL BE RESPONSIBLE FOR THE COST OF LOCATING AND MARKING ALL EXISTING UNDERGROUND UTILITIES.
5. CONTRACTOR SHALL SUBMIT AT LEAST THREE (3) COPIES OF SHOP DRAWINGS FOR ALL MATERIALS TO YORK COUNTY ENGINEERING FOR APPROVAL PRIOR TO CONSTRUCTION.
6. CONTRACTOR SHALL CONDUCT A PRE-CONSTRUCTION CONFERENCE ON SITE WITH THE ENGINEER OF RECORD, YORK COUNTY, AND OTHER INTERESTED PARTIES PRIOR TO CONSTRUCTION.
7. CONNECTION TO ANY EXISTING LINES SHALL BE BY THE CONTRACTOR IN THE PRESENCE OF YORK COUNTY INSPECTION PERSONNEL. PLUG NEW CONNECTION UNTIL CONSTRUCTION AND TESTING HAS BEEN COMPLETED, INSPECTED BY THE ENGINEER OF RECORD AND YORK COUNTY, AND FINAL CONNECTION IS AUTHORIZED.
8. MAINTAIN 18 INCH VERTICAL SEPARATION BETWEEN STORM AND SANITARY SEWER OR INSTALL DUCTILE IRON PIPE ON SANITARY SEWER WITHIN 10 FEET EACH SIDE OF CROSSING.
9. UTILITY SERVICES SHALL NOT BE LOCATED UNDER DRIVEWAYS.
10. YORK COUNTY SHALL OWN AND MAINTAIN THE PROPOSED WATER AND SANITARY SEWER LINE UPON COMPLETION, INSPECTION, APPROVAL, AND ACCEPTANCE.
11. ALL UTILITIES OUTSIDE OF THE PROPOSED ROADWAY MUST BE REVIEWED SEPARATELY UNDER THE YORK COUNTY COMMERCIAL REVIEW PROCESS.
12. THE PROPOSED WATER AND SEWER LINES BEYOND THE METER AND/OR MAIN LINE CONNECTION POINTS WILL NOT BE OWNED, OPERATED, OR MAINTAINED BY YORK COUNTY.
13. WATER MAINS, WITHIN OR PARALLEL TO ROAD RIGHTS OF WAY, MUST HAVE A MINIMUM OF 36" COVER MEASURED FROM THE ROAD EDGE OF PAVEMENT ELEVATION.
14. PRIOR TO BEGINNING CONSTRUCTION OF ANY WATER AND SEWER INFRASTRUCTURE, COPIES OF THE SCDHEC PERMITS TO CONSTRUCT MUST BE PROVIDED TO THE YORK COUNTY ENGINEERING DEPARTMENT.
15. ALL UNDERGROUND PIPING TO HAVE A 14 GAUGE INSULATED SOLID COPPER WIRE INSTALLED PER COUNTY SPECIFICATIONS TO AID IN LOCATING THE PIPE FOR MAINTENANCE PURPOSES.
16. ALL SERVICE LINES REQUIRE INDIVIDUAL CONNECTIONS TO THE MAIN. MULTIPLE SERVICE LINES INTERCONNECTING WILL NOT BE ALLOWED.

REVISIONS

NO.	DATE	DESCRIPTION
1	11/07	ADDED NOTES
2	3/10	ADDED NOTES
3	4/15	ADDED NOTES

**YORK COUNTY
ENGINEERING
STANDARDS**

**WATER/SEWER
GENERAL NOTES**

STD. NO.
10.01
DATE
09/06