



NOTES:
 1. A 14 GAUGE INSULATED SOLID COPPER WIRE SHALL BE LAID ON TOP OF THE PIPE TO AID IN LOCATING THE PIPE FOR MAINTENANCE PURPOSES. THE WIRE SHALL BE SECURED TO THE PIPE WITH DUCT TAPE NEAR EVERY BELL AND AT THE CENTER OF EACH PIPE JOINT. THE WIRE SHALL BE FASTENED SECURELY TO A CAST IRON FITTING AT EACH MAIN LINE VALVE AND FIRE HYDRANT AND TO SERVICE LINES AS DIRECTED BY THE SCDHEC (R.61-58.4D.(11)(G) AND YORK COUNTY SPECIFICATIONS.

REVISIONS

NO.	DATE	DESCRIPTION
1	3/10	ADDED NOTE
2	12/13	REVISED NOTE 1

**YORK COUNTY
 ENGINEERING
 STANDARDS**

**SERVICE CONNECTION
 3/4" AND 1" METER**

STD. NO.	11.17
DATE	09/06