



NOTES:

1. BOLTS TO BE STAINLESS STEEL.
2. INSTALLATION TO INCLUDE TEST PLUG.
3. FLANGE MAY BE DUCTILE IRON INSTEAD OF STAINLESS.
4. PRIOR TO TAPPING THE LINE, PROVIDE A HYDROSTATIC TEST ON THE SLEEVE PER YORK COUNTY SPECIFICATIONS.
5. MECHANICAL JOINT SLEEVE REQUIRED IF NEW PIPE DIAMETER MATCHES EXISTING PIPE DIAMETER.

ELEVATION
N.T.S.

REVISIONS

NO.	DATE	DESCRIPTION
1	5/16	ADDED NOTE 5

**YORK COUNTY
ENGINEERING
STANDARDS**

TAPPING SLEEVE AND VALVE
SEWER FORCEMAIN

STD. NO.
13.09
DATE
09/06