



- NOTES:**
1. BOTTOM SECTION TO BE CENTERED OVER NUT, NOT TO BEAR ON VALVE BODY.
 2. PROVIDE CLEARANCE BETWEEN VALVE BOX/BRICK AND THE VALVE.
 3. WHEN OPERATION NUT DEPTH EXCEEDS 4'-0" BELOW FINISHED GRADE, PROVIDE EXTENSION STEM WITH STD. 2" SQ. OPERATION NUT IN TOP SECTION OF VALVE BOX. EXTENSION STEM SHALL BE SIZED AS RECOMMENDED BY THE VALVE MANUFACTURER.
 4. SEE DETAIL 11.02 FOR VALVE BOX SPECIFICATIONS.

NO.	DATE	DESCRIPTION
1	8/08	CORRECTED TYPO

REVISIONS
EXTENSION USING
PVC (C-900) PIPE
N.T.S.

EXTENSION USING SOIL PIPE
N.T.S.

YORK COUNTY ENGINEERING
STANDARDS

WATER VALVE BOX
INSTALLATION DETAIL

STD. NO.	11.01
DATE	09/06