



- NOTES:
1. CONTRACTOR MAY SUBSTITUTE CONCRETE RESTRAINT BLOCKING AT THE HYDRANT ELBOW WITH MECHANICAL JOINT RESTRAINTS (MEGALUG SERIES 1100). A BLOCK MUST BE INSTALLED TO SUPPORT THE ELBOW.
 2. ALL FIRE HYDRANTS AND ASSEMBLIES EXPOSED TO VIEW SHALL BE PAINTED WITH 2 OR MORE COATS OF WHITE HYDRANT ENAMEL PAINT.
 3. FIRE HYDRANT OPERATING NUT AND ALL VALVES SHALL BE LEFT-HAND OPEN.
 4. PROTECT ALL BOLTS AND THREADS FROM CONCRETE.
 5. PIPING FROM MAIN TO HYDRANT ASSEMBLY TO BE DUCTILE IRON.

REVISIONS

NO.	DATE	DESCRIPTION
1	3/09	ADDED NOTE #5

SECTION VIEW
N.T.S.

YORK COUNTY ENGINEERING
STANDARDS

FIRE HYDRANT
DEEP-BURY DETAIL

11.21	DATE
07/08	DATE