



REVISIONS

| NO. | DATE | DESCRIPTION |
|-----|------|-------------|
| | | |
| | | |

ELEVATION VIEW
N.T.S.

- NOTES:
1. FLEXIBLE COUPLING SHALL BE LONG BODY TYPE.
 2. MINIMUM DEPTHS SHALL BE IN UNDISTURBED SOIL.
 3. MAXIMUM HEIGHT FROM PIPE TO UNDISTURBED SOIL IS 20 FEET.
 4. STEEL PIPE MUST BE SEAMLESS OR STRAIGHT-SEAM. SPIRAL WELD IS NOT PERMITTED.

YORK COUNTY ENGINEERING
STANDARDS

CREEK CROSSING
ON STEEL H-PILES

| | |
|----------|-------|
| STD. NO. | 15.04 |
| DATE | 10/06 |