

ACCT NO \_\_\_\_\_

**YORK COUNTY WATER & SEWER APPLICATION**  
803.327.8639 or 803.628.3211 or 803.909.7280 or 803.909.7275  
*Please remit application and check for the total due to:*  
**1070 Heckle Blvd., Suite 101, Box 10 Rock Hill, SC 29732**

ACCOUNT NAME : \_\_\_\_\_

ADDRESS FOR SERVICE: \_\_\_\_\_

CITY: \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_

MAILING ADDRESS (IF DIFFERENT): \_\_\_\_\_

CITY: \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_

TELEPHONE NUMBER: (\_\_\_\_) \_\_\_\_\_ FAX NUMBER: (\_\_\_\_) \_\_\_\_\_

TAP FEE FOR IRRIGATION SERVICE \$ 550.00

ACTIVATION FEE \$ 30.00

**TOTAL** \$ 580.00

I HAVE RECEIVED A COPY OF THE CURRENT WATER RESTRICTIONS FOR YORK COUNTY WATER/SEWER & AGREE TO COMPLY WITH THESE RESTRICTIONS OR I MAY BE FINED ACCORDING TO THE DROUGHT ORDINANCE.

APPLICANT SIGNATURE\*\*

**\*\*Applicant hereby agrees to adhere to the York County Water & Sewer ordinance and policies**

**\*\*Applicants applying for irrigation service agree to have a Double Check Valve installed within 30 days of installation.**

**\*\*Applicants applying for irrigation service are responsible for attaching irrigation meter to any device.**

**In most cases, meter will be installed within one week of receipt of application and payment.**

-----  
\*FOR OFFICE USE ONLY

Payment Method \_\_\_\_\_ Amount Received \_\_\_\_\_

Received By: \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_



Dear York County Water & Sewer Customer:

On June 13, 2000 the South Carolina Department of Health and Environmental Control (SCDHEC) issued a directive that all irrigation meters must be equipped with a backflow preventer. SCDHEC states that a double check valve may be used as a backflow preventer and that is what we recommend you use.

The homeowner or the company installing an irrigation system may install the double check valve. York County Water & Sewer will ***not*** be responsible for installing the double check valve or connecting the meter to a faucet or irrigation system. A list of SCDHEC approved double check valves is included. **If the double check valve is not installed within 30 days of receiving your irrigation meter, the meter will be removed.** The meter will not be replaced until the double check valve is in place and a reconnect fee of \$50 is collected.

Our department will send you notification of when the testing is to be done. A list of certified testers in the area will be sent with the notification. **The homeowner will be responsible for paying for the cost of the test.**

If you have any questions, please do not hesitate to contact John McCraw, York County Water & Sewer Assistant Supervisor, or me at (803) 327-8639. We would like to thank you in advance for your cooperation.

Sincerely,  
Theresa Jenkins  
York County Water & Sewer Office Coordinator/Billing Clerk

SCDHEC

LIST OF APPROVED BACKFLOW PREVENTION DEVICES

DOUBLE CHECK VALVE ASSEMBLIES

Approved for use to protect the potable water system from backflow when a low degree of hazard is involved. A low degree of hazard is one which may cause an actual or potential threat to the physical properties of the water system or the potability of the public or consumer's potable water system. However, a low degree of hazard would not constitute a health or system hazard. The maximum degree or density of pollution to which the potable water system could be degraded under this definition would cause a nuisance or be aesthetically objectionable.

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Ames	2000 (Epoxy)	4", 6", 8", 10"
	2000SS	¾", 1", 1 ¼", 1 ½", 2", 2 ½", 3", 4", 6", 8", 10"
	2000SE	6", 8"
Beeco-Hersey	#2	3", 4", 6", 8", 10"
	FDC	¾", 1", 1 ½", 2"
Buckner	24100 thru 24104	¾", 1", 1 ½", 2"
Cla-Val	D	1", 2", 2 ½", 3", 4", 6", 8", 10"
	DC6LB	¾", 1", 1 ½", 2"
	DC6LW	¾", 1", 1 ½", 2"
	DC7LW	2 ½", 3", 4", 6", 8", 10"
	DC7LY	2 ½", 3", 4", 6", 8", 10"
	DC8LW	2 ½", 3", 4", 6", 8", 10"
	DC8NW	2 ½", 3", 4", 6", 8", 10"
Conbraco	40-100 Series	½", ¾", 1", 1 ½", 2"
		2 ½", 3", 4", 6", 8", 10"
(Top-Entry)	40-104 A2T thru- 40-108 A2T	¾", 1", 1 ¼", 1 ½", 2"
Febco	805-Y	¾", 1", 1 ½", 2", 2 ½" 3", 4", 6", 8", 10"
	850	4", 6", 8"
	870	2 ½", 3", 4", 6", 8"
	870-V	2 ½", 3", 4", 6", 8"

## DOUBLE CHECK VALVE ASSEMBLIES CONTINUED

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Flomatic	B 9100 thru B 9104	¾", 1", 1 ½", 2"
Wilkins	550 950	¾", 1", 1 ¼", 1 ½", 2", 2 ½", 3", 4", 6" ¾", 1", 1 ¼", 1 ½", 2", 2 ½", 3" 4", 6", 8", 10"
Watts	709QT Series 709RW Series 007QT Series 007RW Series 770RW Series 772RW Series	¾", 1", 1 ¼", 1 ½", 2" 2 ½", 3", 4", 6", 8", 10" ¾", 1", 1 ½", 2" 2 ½", 3" 4", 6", 8" 4", 6", 8", 10"

### DESIGNATIONS:

QT-Quarter Turn Ball Valves

BV-Ball Valve

R-Resilient Seated Gate Valves

RW-Resilient wedge gate valves in either NRS or OS&Y

The following devices are Double DETECTOR Check Valve Assemblies. These devices are made up from approved DCVA's which are approved elsewhere on this list. Therefore, they are approved devices. The devices are only designed for FIRE LINE use. If a Double Detector Check Valve Assembly is prescribed for a given facility on your system, it should be done with an understanding of the purpose of this device, as well as the fact that it's meter will have to be read periodically to be of any value. Double DETECTOR Check Valve Assemblies are:

AMES – 3000SS and 3000SE

BECO-HERSEY – DDCII

CONBRACO – 40-600

FEBCO – 806YD, 856, 676, and 876-V

WILKINS – 950DAR

WATTS – 709DCDA, 770DCDA, 772DCDA

CLA-VAL – DD2LY, DD8LY, DD8NY